

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3230-0981:108

Page 1 of 1

CATEGORY: Leakage Dampers

LISTEE: Greenheck Fan Corp., 400 Ross Ave., Schofield WI 54476-0410
Contact: Marty Gissel (715) 355-6611 Fax (715) 355-3954

DESIGN: Model *SMD-401 is a multi-blade leakage rated damper. Refer to listee's data sheet for detailed product description and operational considerations.

RATING:	<u>Model</u>	<u>Single Sec.</u>		<u>Double Sec.</u>		Rated	Installation
		W	H	W	H		
	*SMD-401	48"	60"	96"	72"	I-250	V or H

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction. For vertical and horizontal installation.

MARKING: Listee's name, model number, classification and UL label.

APPROVAL: Listed as leakage dampers for use as described under "Design" and "Installation".

*Rev. 12-22-2002 JEW



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **DECEMBER 22, 2002**

Listing Expires **June 30, 2003**

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager